



## **2024 Consumer Confidence Report Tryon Road Special Utility District**

**This is your water quality report for January 1 to December 31, 2024**

Tryon Road SUD provides surface water and ground water from Lake O' the Pines and Carrizo-Wilcox Aquifer in Gregg County.

For More Information regarding this report, contact:  
Will Hobbs, General Manager  
903-663-1447

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (903) 663-1447.



## Definitions and Abbreviations

The following tables contain scientific terms and measures, some of which may require explanation.

**Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Avg:** Regulatory compliance with some MCLs are based on running annual average of monthly samples.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**Maximum Contaminant Level or MCL:** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal or MCLG:** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum residual disinfectant level or MRDL:** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum residual disinfectant level goal or MRDLG:** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.



## Definitions and Abbreviations (contd.)

MFL:	million fibers per liter (a measure of asbestos)
mrem:	millirems per year (a measure of radiation absorbed by the body)
na:	not applicable
NTU:	nephelometric turbidity units (a measure of turbidity)
pCi/L:	picocuries per liter (a measure of radioactivity)
ppb:	micrograms per liter or parts per billion- or one ounce in 7,350,000 gallons of water
ppm:	milligrams per liter or parts per million- or one ounce in 7,350 gallons of water
ppq:	parts per quadrillion, or picograms per liter (pg/L)
ppt:	parts per trillion, or nanograms per liter (ng/L)
Treatment Technique or TT:	A required process intended to reduce the level of contaminants in drinking water.

## Information about your Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, or residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact Tryon Road SUD's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.



## Information about Source Water

Tryon Road SUD purchases water from NORTHEAST TEXAS MWD. NORTHEAST TEXAS MWD provides purchase surface water from Lake O' the Pines located in Morris, Upshur, and Marion County.

The NETMWD plant at Lake O' the Pines, a surface water source, or Tanner Plant, recorded no violations or positive Bac-T's in 2024.

NETMWD received a violation in 2024 for "failure to submit Initial Lead Service Inventory". NETMWD is a wholesale distributor of water and therefore had not service lines that would contain lead. They received the notice of non-compliance on January 9, 2025 and it was resolved on January 10, 2025.

TRSUD is participating in the UCMR5 data collection with the EPA. TRSUD will provide the results of the testing when they become available.

As required by the TCEQ, TRSUD prepared at Lead Line Inventory of our system. TRSUD found no lead, galvanized requiring replacement, or unknown service lines.



TCEQ completed an assessment of your source water, and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system, contact Will Hobbs, General Manager, at 903-663-1447.

### Coliform Bacteria

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli Maximum Contaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	1 Positive Monthly Sample	1		0	N	Naturally present in the environment

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90 <sup>th</sup> Percentile	# of Sites over AL	Units	Violations	Likely Source of Contamination
Copper	08/17/22	1.3	1.3	0.054	0	ppm	N	Erosion of natural deposits; leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	08/17/22	0	15	0	2	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits



Disinfection By-products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2024	35	17.7-49.6	No goal for the total	60	ppb	N	By-product of drinking water disinfection.

\*The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year.

Total Trihalomethanes (TTHM)	2024	30	7.52-56.5	No goal for the total	80	ppb	n	By-product of drinking water disinfection
------------------------------	------	----	-----------	-----------------------	----	-----	---	---

\*The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year.

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	08/10/2023	0.063	0.063-0.063	2	2	ppm	N	Discharge of drilling wastes; discharge from metal refineries; Erosion of natural deposits.
Chromium	08/10/2023	2.5	2.5-2.5	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits.
Cyanide	08/10/2023	82.8	0-82.8	200	200	ppb	N	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories.

Fluoride	08/10/2023	0.0878	0.0878-0.0878	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2024	0.264	0.111-0.264	10	10	ppm	N	Runoff from fertilizer use; leaching from septic tanks, sewage; Erosion of natural deposits

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/photon emitters	10/24/22	7	0-7	0	50	pCi/L*	N	Decay of natural and man-made deposits

\* EPA considers 50 pCi/L to be the level of concern for beta particle.

### Disinfectant Residual

Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Units of Measure	Violation	Source in Drinking Water
Chloramines	2024	2.44	1.38-3.06	4	4	ppm	N	Water Additive used to control microbes



**Tryon Road Special Utility District PWS TX0920021**

**360 Skinner Lane**

**Longview, Texas 75605**

**(903) 663-1447**

**Website: [www.tryonroadsud.org](http://www.tryonroadsud.org)**

**2024 Consumer Confidence Report**

**Tryon Road Special Utility District**